

The following chart suggests general light levels and is for preliminary guidance only. For specific applications, please check the relevant standards and recommendations or contact Veelite.

INTERNAL APPLICATION	CLASS/LEVEL	LIGHT LEVELS
General Industry (Note 1)	-	300 Lux
Retail Stores	-	500 Lux
Supermarkets	-	750 Lux
School Assembly Halls	-	300 Lux
Entrances/Exits/Canteens	-	200 Lux
Restrooms	-	150 Lux
Corridor Areas/Toilets		100 Lux
Warehouses:		
Working/Packing/Despatch	-	300 Lux
Small Item Storage	-	300 Lux
Reading Necessary/no small items	-	200 Lux
Search Only	-	100 Lux
Offices	-	500 Lux
Counter Areas	-	500 Lux
Filing/Print Rooms	-	300 Lux
Carparks:		
Parking Bays & Driving Lanes	-	75 Lux
Entrances & Exits	-	250 - 300 Lux
Restaurants & Hotels:		
Food Preparation & Cooking	-	500 Lux
Wash Up/Vegetable Preparation	-	300 Lux
Food Storage Areas/Cellars	-	150 Lux
Bedrooms	-	50 - 100 Lux
Bars, Dining Rooms	-	50 - 200 Lux
Sports:		
Badminton:	National/Intn	750 Lux
	Regional/Local	500 Lux
	Local /Training	300 Lux
Swimming:	National/Intn	750 Lux
	Regional/Local	500 Lux
	Local /Training	200 Lux

EXTERNAL APPLICATION	CLASS/LEVEL	LIGHT LEVELS
Canopied Areas	-	150 Lux
Facade Floodlighting (Note 3)	-	50 Lux - 1500 Lux
Carparks:		
Urban Areas	-	20 Lux
Roof of Multi-storey	-	20 Lux
Rural Areas	-	10 Lux
Roadways (Note 4):		
City Centre	-	30 Lux
Suburban	-	20 Lux
Village	-	15 Lux
Sports:		
Football/Rugby:	Nat/Intn	500 Lux
	Regional/Local	200 Lux
	Local/Training	75 Lux
Tennis:	Nat/Intn	500 Lux
	Regional/Local	300 Lux
	Local/Training	200 Lux
Equestrian:	Nat/Intn	500 Lux
	Regional/Local	200 Lux
	Local/Training	100 Lux

Notes:

3). Depends on Local light levels & surface of building.

4). Vehicular & Pedestrian Traffic.

Notes:

1). Varies from 300 Lux to 1500 Lux depending on the nature of the work.

2). Light Levels in different areas must also be in relation to each other to avoid contrasts.